

Annual
**WATER
QUALITY
REPORT**
Reporting Year 2012



Presented By _____
Chelmsford Water District

PWS ID#: 3056000

There When You Need Us

We are once again proud to present our annual water quality report covering all testing performed between January 1 and December 31, 2012. Over the years, we have dedicated ourselves to producing drinking water that meets all state and federal standards. We continually strive to adopt new methods for delivering the best-quality drinking water to you. As new challenges to drinking water safety emerge, we remain vigilant in meeting the goals of source water protection, water conservation, and community education while continuing to serve the needs of all our water users.

Please remember that we are always available to assist you should you ever have any questions or concerns about your water.

Community Participation

You are invited to participate in our public forum and voice your concerns about your drinking water. We meet the second Wednesday of each month beginning at 4 p.m. at the Chelmsford Water District, 20 Watershed Lane, Chelmsford, MA.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or <http://water.epa.gov/drink/hotline>.

Substances That Could Be in Water

To ensure that tap water is safe to drink, the Department of Environmental Protection (DEP) and the U.S. Environmental Protection Agency (U.S. EPA) prescribe regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) and Massachusetts Department of Public Health (DPH) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and which may also come from gas stations, urban stormwater runoff, and septic systems;

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Source Water Assessment

The Source Water Assessment and Protection (SWAP) program assesses the susceptibility of public water supplies to potential contamination due to land uses and activity within the recharge areas. Established under the federal Safe Drinking Water Act, the program requires every state to inventory land uses within the recharge areas of all public water supply sources, to assess the susceptibility of drinking water sources to contamination from these land uses, and to publicize the results to provide support for improved protection.

What Is My System's Ranking?

A susceptibility ranking of high was assigned to this system using the information collected during the assessment by the Massachusetts Department of Environmental Protection (DEP).

Where Can I See the SWAP Report?

The complete SWAP report is available at the Chelmsford Water District, at the Chelmsford Board of Health, and online at www.mass.gov/dep/water/drinking/3056000.pdf. For more information, call Superintendent Delaney at (978) 256-2931.

QUESTIONS?

For more information about this report, or any questions relating to your drinking water, please contact us at (978) 256-2381 or visit our website at www.chelmsfordwater.com.

Fact or Fiction

Water treatment began as a way to remove disease-causing agents. *(Fiction: It was only in the 1950s that scientists began to suspect that water might carry diseases. Although earlier treatment of water could make the water safer, it was mainly done merely to improve the taste, smell, or appearance of the water.)*

About half of the world's water supply is available for drinking. *(Fiction: If all the world's water were fit into a gallon jug, the fresh water available for us to use would equal only about one tablespoon.)*

Due to its unique nature, water boils at the same temperature anywhere on the planet. *(Fiction: At sea level, water boils at 212 degrees Fahrenheit, but on top of Mt. Everest, water boils at 154 degrees.)*

Water regulates the temperature of the Earth. *(Fact: As in the human body, the water in our oceans, lakes, and streams plays a major role in regulating planetary temperatures.)*

The Mississippi River is longer than the Amazon River. *(Fiction: At 3,902 miles the Mississippi River is not as long as the Amazon River, which flows for 4,000 miles.)*

Forty trillion gallons of water a day are carried in the atmosphere across the United States. *(Fact: Forty percent of the atmosphere's moisture content falls as precipitation each day.)*

How Is My Water Treated and Purified?

The Crooked Spring Treatment Plant went online in the spring of 2007. Nine of the District's wells are processed through this plant, including the four gravel-packed wells at the Meadowbrook #3 pumping station that went on line in November of 2007. The raw water goes through an aeration tower, removing any potential volatile organic compounds. Then the water goes through a greensand filtration system, removing high levels of iron and manganese before the water enters the distribution system. This plant recycles the backwash discharged water to a lagoon, from which it then re-enters the earth and becomes part of the aquifer.

Raw water is drawn from the other eight wells in the eastern area of the district and is sent through the greensand filtration system at the Riverneck Road Treatment Plant to remove elevated levels of iron and manganese from these wells. In addition, the treatment plant treats the two wells on Canal Street that were out of service for many years because of poor water quality. The filtration process also incorporates an aeration tower to remove low levels of volatile organic compounds from the raw water. The backwash water generated from the treatment process is stored in an on-site 100,000-gallon underground storage facility. The facility has the capability of pumping all of the water to the nearby public sewer, or recycling the water to the treatment plant.

The Smith Street Treatment Plant and Wells, after being unused since 1999, were re-opened in the fall of 2012 with DEP approval. The District has refurbished the wells and retrofitted the treatment system over the past year. The raw water enters the Smith Street Treatment Plant which is serviced by an aeration and membrane filtration system to remove iron and manganese. This plant and wells now allow for system relief during times of withdrawal stress and allow emergency back up for both the Crooked Spring and Riverneck Road Treatment Plants.

Faced with deteriorating water quality and increasing peak demands for water during daytime hours, the Board of Water Commissioners has made and kept the commitment to our customers to provide treatment for all the district's wells. All of Chelmsford Water District's water is now processed and treated through state-of-the-art treatment facilities.

Where Does My Water Come From?

The Chelmsford Water District customers are fortunate because we enjoy an abundant water supply from 19 sources. The Chelmsford Water District draws water from the Merrimack and Concord river basins. Our reservoirs hold one of the state's largest capacities: 15 million gallons of water. Combined, our facilities provide roughly 1 billion gallons of clean drinking water each year. The Riverneck Road Treatment Plant was placed in service at the end of 2004 and treats 3 million gallons of water per day. The Crooked Spring Treatment Plant was placed in service in the spring of 2007 and treats 4 million gallons a day. The Smith Street Treatment Plant was refurbished and put back into services in the fall of 2012. To learn more about our watershed, visit the U.S. EPA website at www.epa.gov/surf.

Water Main Flushing

Distribution mains (pipes) convey water to homes, businesses, and hydrants in your neighborhood. The water entering distribution mains is of very high quality; however, water quality can deteriorate in areas of the distribution mains over time. Water main flushing is the process of cleaning the interior of water distribution mains by sending a rapid flow of water through the mains.

Flushing maintains water quality in several ways. For example, flushing removes sediments like iron and manganese. Although iron and manganese do not pose health concerns, they can affect the taste, clarity, and color of the water. Additionally, sediments can shield microorganisms from the disinfecting power of chlorine, contributing to the growth of microorganisms within distribution mains. Flushing helps remove stale water and ensures the presence of fresh water with sufficient dissolved oxygen, disinfectant levels, and an acceptable taste and smell.

During flushing operations in your neighborhood, some short-term deterioration of water quality, though uncommon, is possible. You should avoid tap water for household uses at that time. If you do use the tap, allow your cold water to run for a few minutes at full velocity before use and avoid using hot water, to prevent sediment accumulation in your hot water tank.

Please contact us if you have any questions or if you would like more information on our water main flushing schedule.



What is the typical per-day water usage?

While usage varies from community to community and person to person, on average, Americans use 183 gallons of water a day for cooking, washing, flushing, and watering purposes. The average family turns on the tap between 70 and 100 times daily. About 74% of home water usage occurs in the bathroom, about 21% in the laundry room, and about 5% in the kitchen.

Why do water pipes tend to break in winter?

Liquids generally contract when frozen and become more dense; however, the unique qualities of water cause it to expand by up to 9% when it freezes. That is why water pipes burst when temperatures reach the freezing mark.

How much water is used to create the food we eat each year?

The average American consumes 1,500 pounds of food each year; 1,000 gallons of water are required to grow and process each pound of that food. Thus, 1.5 million gallons of water is invested in the food eaten annually by just one person! This 200,000-plus cubic feet of water per person is enough to cover a football field four feet deep.

Is it okay to use hot water from the tap for cooking and drinking?

No, ALWAYS use cold water. Hot water is more likely to contain rust, copper, and lead from household plumbing and water heaters. These harmful substances can dissolve into hot water faster than they do into cold water, especially when the faucet has not been used for an extended period of time.

What type of container is best for storing water?

Consumer Reports has consistently advised that glass or BPA-free plastics such as polyethylene are the safest choices. To be on the safe side, do not use any container with markings on the recycle symbol showing 7 PC (which is the code for BPA). You could also consider using stainless steel or aluminum containers that have BPA-free liners.

Sampling Results

During the past year, we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic, or synthetic organic contaminants. The tables below show only those contaminants that were detected in the water.

The state requires us to monitor for certain substances less often than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

REGULATED SUBSTANCES							
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	MCLG [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Arsenic (ppb)	2012	10	0	1	ND–1	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2012	2	2	0.04	ND–0.04	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Haloacetic Acids [HAAs] (ppb)	2012	60	NA	4.75	ND–22.5	No	By-product of drinking water disinfection
Nitrate (ppm)	2012	10	10	1.00	ND–1.00	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TTHMs [Total Trihalomethanes] (ppb)	2012	80	NA	49.3	ND–85.3	No	By-product of drinking water disinfection

Tap water samples were collected for lead and copper analyses from sample sites throughout the community

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	MCLG	AMOUNT DETECTED (90TH%TILE)	SITES ABOVE AL/ TOTAL SITES	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2011	1.3	1.3	0.079	0/30	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppb)	2011	15	0	2	0/30	No	Corrosion of household plumbing systems; Erosion of natural deposits

SECONDARY SUBSTANCES							
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	SMCL	MCLG	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Iron (ppb)	2012	300	NA	70	ND–70	No	Leaching from natural deposits; Industrial wastes
Manganese (ppb)	2012	50	NA	46	ND–46	No	Leaching from natural deposits

UNREGULATED SUBSTANCES ¹				
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
Bromodichloromethane (ppb)	2012	19.0	ND–19.0	Disinfection by-product
Chloroform (ppb)	2012	34.0	ND–34.0	Disinfection by-product
Dibromochloromethane (ppb)	2012	4.4	ND–4.4	Disinfection by-product
Sodium (ppm)	2012	69	59–69	Naturally occurring

¹ Unregulated contaminants are those for which the U.S. EPA has not established drinking water standards. The purpose of monitoring unregulated contaminants is to assist the U.S. EPA in determining their occurrence in drinking water and whether future regulation is warranted.

Definitions

90th Percentile: Out of every 10 homes sampled, 9 were at or below this level.

AL (Action Level): The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable

ND (Not detected): Indicates that the substance was not found by laboratory analysis.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).