

A close-up photograph of an adult's hand holding a clear glass filled with water. A child's hand is reaching up from the bottom left, with fingers touching the bottom of the glass. The background is a soft, out-of-focus green, suggesting an outdoor setting with foliage.

Presented By
Chelmsford Water District

ANNUAL
**WATER
QUALITY
REPORT**

WATER TESTING PERFORMED IN 2015

Meeting the Challenge

Once again we are proud to present our annual drinking water report, covering all drinking water testing performed between January 1 and December 31, 2015. Over the years, we have dedicated ourselves to producing drinking water that meets all state and federal standards. We continually strive to adopt new methods for delivering the best quality drinking water to your homes and businesses. As new challenges to drinking water safety emerge, we remain vigilant in meeting the goals of source water protection, water conservation, and community education while continuing to serve the needs of all of our water users.

Please remember that we are always available to assist you, should you ever have any questions or concerns about your water.

Community Participation

You are invited to participate in our public forum and voice your concerns about your drinking water. We meet the second Wednesday of each month beginning at 4 p.m. at the Chelmsford Water District, 20 Watershed Lane, Chelmsford, MA.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or <http://water.epa.gov/drink/hotline>.



Substances That Could Be in Water

To ensure that tap water is safe to drink, the Department of Environmental Protection (DEP) and the U.S. Environmental Protection Agency (U.S. EPA) prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) and Massachusetts Department of Public Health (DPH) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and which may also come from gas stations, urban stormwater runoff, and septic systems;

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

Where Does My Water Come From?

The Chelmsford Water District customers are fortunate because we enjoy an abundant water supply from 19 sources. The Chelmsford Water District draws water from the Merrimack and Concord river basins. Our reservoirs hold one of the states largest capacities, 15.3 million gallons of water. Combined, our facilities provide roughly 1 billion gallons of clean drinking water each year. The Riverneck Road Treatment Plant was placed in service at the end of 2004 and treats 3 million gallons of water per day. The Crooked Spring Treatment Plant was placed in service in the spring of 2007 and treats 4 million gallons a day. The Smith Street Treatment Plant was refurbished and put back into services in the fall of 2012. To learn more about our watershed visit the U.S. EPA website at www.epa.gov/surf.

What's Your Water Footprint?

You may have some understanding about your carbon footprint, but how much do you know about your water footprint? The water footprint of an individual, community, or business is defined as the total volume of freshwater that is used to produce the goods and services that are consumed by the individual or community or produced by the business. For example, 11 gallons of water are needed to irrigate and wash the fruit in one half-gallon container of orange juice. Thirty-seven gallons of water are used to grow, produce, package, and ship the beans in that morning cup of coffee. Two hundred and sixty-four gallons of water are required to produce one quart of milk, and 4,200 gallons of water are required to produce two pounds of beef.

According to the U.S. EPA, the average American uses over 180 gallons of water daily. In fact, in the developed world, one flush of a toilet uses as much water as the average person in the developing world allocates for an entire day's cooking, washing, cleaning, and drinking. The annual American per capita water footprint is about 8,000 cubic feet; twice the global per capita average. With water use increasing six-fold in the past century, our demands for freshwater are rapidly outstripping what the planet can replenish.

To check out your own water footprint, go to www.gracelinks.org/824/water-program or visit www.waterfootprint.org to see how the water footprints of other nations compare.

Ground Water Sampling

On June 10 and July 8, 2015, the District was informed that one of our routine bacteria samples of our untreated source water collected on the associated dates of June 9 and July 7, 2015, were positive for fecal contamination (*E. coli*). With the knowledge that the District's untreated water is vulnerable to this type of contamination and since the enacting of the Ground Water Rule, the Chelmsford Water District has ensured that its treated water through disinfection practices is and remains safe by being 4-log certified by state agencies as of February 24, 2010. The District maintains this certification on a day to day basis and reports this status to the state monthly. Since the District is in compliance with the Ground Water Rule in respect to this certification, no other steps were or are required. The reporting of these positive results is for informational purposes only and a regulation requirement. At no time was the public's health at risk.

Fecal indicators are microbes whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

Information on the Internet

The U.S. EPA (www.epa.gov/Your-Drinking-Water) and the Centers for Disease Control and Prevention (www.cdc.gov) Web sites provide a substantial amount of information on many issues relating to water resources, water conservation and public health. Also, the DEP has a Web site (www.mass.gov/eea/agencies/massdep/water/drinking) that provides complete and current information on water issues in Massachusetts, including valuable information about our watershed.

QUESTIONS?

For more information about this report, or any questions relating to your drinking water, please contact us at (978) 256-2381 or visit our website at www.chelmsfordwater.com.

How Is My Water Treated and Purified?

The Crooked Spring Treatment Plant went online in the Spring 2007. Nine of the District's wells are processed through this plant. Including the four gravel packed wells at Meadowbrook #3 pumping station that went on line in November 2007. The raw water goes through an aeration tower removing any potential volatile organic compounds, then the water goes through a greensand filtration system removing high levels of iron and manganese before the water enters the distribution system.

This plant recycles the backwash discharged water to a lagoon, which then reenters the earth and becomes part of the aquifer.

Raw water is drawn from the other eight wells in the eastern area of the district and is sent through the greensand filtration system at the Riverneck Road Treatment Plant to remove elevated levels of iron and manganese from these wells. In addition, the treatment plant treats the two wells on Canal Street that were out of service for many years because of poor water quality. The filtration process also incorporates an aeration tower to remove low levels of volatile organic compounds from the raw water. The backwash water generated from the treatment process is stored in an on-site 100,000-gallon underground storage facility. The facility has the capability of pumping all of the backwash water to the nearby public sewer, or recycling the water to the treatment plant.

The Smith Street Treatment Plant and Wells, after being unused since 1999, was reopened in fall 2012 with DEP approval. The District refurbished the wells and retrofitted the treatment system. The Raw Water enters the Smith Street Treatment Plant which is serviced by an aeration and membrane filtration system to remove iron and manganese. This plant and wells allow for system relief during times of withdrawal stress and emergency back up for both the Crooked Spring and Riverneck Road Treatment Plants.

All of Chelmsford Water District's water is processed and treated through state of the art treatment.

Faced with deteriorating water quality and increasing peak demands for water during daytime hours, the Board of Water Commissioners has made and kept the commitment to our customers to provide treatment for all the districts wells.

Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/lead.

Source Water Assessment

The Source Water Assessment and Protection (SWAP) program assesses the susceptibility of public water supplies to potential contamination due to land uses and activity within the recharge areas. Established under the federal Safe Drinking Water Act, the program requires every state to inventory land uses within the recharge areas of all public water supply sources, to assess the susceptibility of drinking water sources to contamination from these land uses, and to publicize the results to provide support for improved protection.

What Is My Systems Ranking?

A susceptibility ranking of high was assigned to this system using the information collected during the assessment by the Massachusetts Department of Environmental Protection (DEP).

Where Can I See the SWAP Report?

The complete SWAP report is available at the Chelmsford Water District, at the Chelmsford Board of Health, and online at www.mass.gov/dep/water/drinking/3056000.pdf. For more information, call Superintendent Delaney at (978) 256-2931.

Failure In Flint

The national news coverage of water conditions in Flint, Michigan, has created a great deal of confusion and consternation over the past year. The water there has been described as being corrosive; images of corroded batteries and warning labels on bottles of acids come to mind. But is corrosive water bad?

Corrosive water can be defined as a condition of water quality, which will dissolve metals (iron, lead, copper, etc.) from metallic plumbing at an excessive rate. There are a few contributing factors but, generally speaking, corrosive water has a pH of less than 7; the lower the pH, the more acidic, or corrosive, the water becomes. (By definition, many natural waterways throughout the country can be described as corrosive.) While all plumbing will be somewhat affected over time by the water it carries, corrosive water will damage plumbing much more rapidly than water with low corrosivity.

By itself, corrosive water is not a health concern; your morning glass of orange juice is considerably more corrosive than the typical lake or river. What is of concern is that exposure in drinking water to elevated levels of the dissolved metals increases adverse health risks. And there lies the problem.

Public water systems are required to maintain their water at optimal conditions to prevent it from reaching corrosive levels. Rest assured that we routinely monitor our water to make sure what happened in Flint never happens here. For more information on how corrosivity impacts water quality, download this informative pamphlet at: pubs.ext.vt.edu/442/442-665/442-665_PDF.pdf.

Water Main Flushing

Distribution mains (pipes) convey water to homes, businesses, and hydrants in your neighborhood. The water entering distribution mains is of very high quality; however, water quality can deteriorate in areas of the distribution mains over time. Water main flushing is the process of cleaning the interior of water distribution mains by sending a rapid flow of water through the mains.

Flushing maintains water quality in several ways. For example, flushing removes sediments like iron and manganese. Although iron and manganese do not pose health concerns, they can affect the taste, clarity, and color of the water. Additionally, sediments can shield microorganisms from the disinfecting power of chlorine, contributing to the growth of microorganisms within distribution mains. Flushing helps remove stale water and ensures the presence of fresh water with sufficient dissolved oxygen, disinfectant levels, and an acceptable taste and smell.

During flushing operations in your neighborhood, some short-term deterioration of water quality, though uncommon, is possible. You should avoid tap water for household uses at that time. If you do use the tap, allow your cold water to run for a few minutes at full velocity before use and avoid using hot water, to prevent sediment accumulation in your hot water tank.

Please contact us if you have any questions or if you would like more information on our water main flushing schedule.

Sampling Results

During the past year, we have taken hundreds of water samples to determine the presence of any radioactive, biological, inorganic, volatile organic or synthetic organic contaminants. The table below shows only those contaminants that were detected in the water. The state requires us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

We participated in the 3rd stage of the EPA's Unregulated Contaminant Monitoring Regulation (UCMR3) program by performing additional tests on our drinking water. UCMR3 benefits the environment and public health by providing the EPA with data on the occurrence of contaminants suspected to be in drinking water, in order to determine if EPA needs to introduce new regulatory standards to improve drinking water quality. Contact us for more information on this program.

REGULATED SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	MCLG [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Barium (ppm)	2015	2	2	0.038	0.008–0.038	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Haloacetic Acids [HAA]–Stage 2 (ppb)	2015	60	NA	24.3	0–24.6	No	By-product of drinking water disinfection
Nitrate (ppm)	2015	10	10	1.4	0.07–1.4	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TTHMs [Total Trihalomethanes]– Stage 2 (ppb)	2015	80	NA	66.5	10.7–83.2	No	By-product of drinking water disinfection

Tap water samples were collected for lead and copper analyses from sample sites throughout the community

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	MCLG	AMOUNT DETECTED (90TH%TILE)	SITES ABOVE AL/TOTAL SITES	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2014	1.3	1.3	0.07	0/30	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppb)	2014	15	0	14	0/30	No	Corrosion of household plumbing systems; Erosion of natural deposits

SECONDARY SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	SMCL	MCLG	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Chloride (ppm)	2015	250	NA	170	128–170	No	Runoff/leaching from natural deposits
Iron (ppb)	2015	300	NA	6	0–6	No	Leaching from natural deposits; Industrial wastes
Manganese (ppb)	2015	50	NA	6	0–6	No	Leaching from natural deposits

UNREGULATED SUBSTANCES ¹

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
Bromodichloromethane (ppb)	2015	10.7	0–10.7	Chlorination By-product
Bromoform (ppb)	2015	1.06	0–1.06	Chlorination By-product
Chloroform (ppb)	2015	22.1	0–22.1	Chlorination By-product
Dibromomethane (ppb)	2015	4.84	0–4.84	Chlorination By-product
Nickel (ppm)	2015	0.008	0.001–0.008	Nickel is a natural element of the earth's crust; therefore, small amounts are found in food, water, soil, and air
Sodium (ppm)	2015	90.1	35.7–90.1	Naturally occurring

UNREGULATED CONTAMINANT MONITORING REGULATION PART 3 (UCMR3)

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
1,4 Dioxane (ppb)	2015	0.09	0–0.09	Cyclic aliphatic ether; used as a solvent or solvent stabilizer in manufacture and processing of paper, cotton, textile products, automotive coolant, cosmetics, and shampoos
Chlorate (ppb)	2015	320	35–320	Agricultural defoliant or desiccant; disinfection by-product
Chromium (ppm)	2015	0.20	0–0.20	Discharge from steel and pulp mills; Erosion of natural deposits
Hexavalent Chromium (ppb)	2015	0.15	0–0.15	Naturally occurring element; used in making steel and other alloys; chromium-3 or -6 forms are used for chrome plating, dyes and pigments, leather tanning, and wood preservation
Strontium (ppb)	2015	200	140–200	Naturally occurring element; historically, commercial use of strontium has been in the faceplate glass of cathode-ray tube televisions to block x-ray emissions

¹ Unregulated contaminants are those for which the U.S. EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist U.S. EPA in determining their occurrence in drinking water and whether future regulation is warranted.

Definitions

90th Percentile: Out of every 10 homes sampled, 9 were at or below this level.

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

LRAA (Locational Running Annual Average): The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).